

# **Certificate of Product Approval**

Certificate Number: 1330h-(cl-4) Issue: 01



# **Tanda Development Pte. Ltd**

21 Bukit Batok Crescent #15-75 Wcega Tower Singapore 658065

is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

### **Products**

**Control & Indicating Equipment** 

(Refer to Appendix for details)

### **Standards**

EN 54-2:1997 + A1:2006

EN 54-4:1997 + A1:2002 + A2:2006

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

E Mattie-Suleiman

27 May 2020 Date of Issue 27 May 2020

Date of First Issue





This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX

T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.







#### Appendix to Certificate No: 1330h-(cl-4) Issue: 01

## **Tanda Development Pte. Ltd**

Certified Product		Description	LPCB Ref.No.
TX7004	1 to 4 loop Inte	lligent Addressable Control and Indicating Equipment	1330h/01
	Incorporating th		
		TX7004 Mother Board	
		TX7004 Main Board	
	7010700017	TX7004 Loop Board	
	7010400011	TX7004 Power Management Board	
	7010600019	TX7004 Communication Board	
	7010400012	TX7004 Power Wiring Board	
	PDF-150-27.5	Power Supply Unit	
	7021300007	TX7004 Key Board	
	7020800009	TX7004 Led Board	
	7010300010	TX7004 Regional Display Board	
	814400002	TX6940E Printer Module	
	Certified with th	ne following options with requirements from EN54-2:	
	7.8 Output to fire alarm device(s)		
	7.10.1 Output to fire protection equipment - Type A		
	7.11 Delays to outputs		
	7.12.1 Dependencies on more than one alarm signal- Type A		
	7.12.2 Dependencies on more than one alarm signal -Type B		
	7.13 Alarm counter		
	9.5 Disablement of each address point		
	10 Test condition		

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

E Mattie-Suleiman

27 May 2020

27 May 2020

Signed for BRE Global Ltd

Date of Issue

Date of First Issue





This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX

T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.







## Appendix to Certificate No: 1330h-(cl-4) Issue: 01

## **Tanda Development Pte. Ltd**

Certified Product	Description	LPCB Ref.No.
	Note:  1. The scope of the approval does not include the operation of the network functionality  2. The product approval does not constitute compliance with the fire detection and alarm system requirements of EN54-13.	

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

F.Man.

E Mattie-Suleiman

27 May 2020

27 May 2020

Signed for BRE Global Ltd

Verifier

Date of Issue

Date of First Issue





This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX

T: +44 (0)333 321 8811 E: enquiries@breglobal.com



